Date



Republic of the Philippines GENERAL SANTOS CITY WATER DISTRICT

E. Fernandez Street, Barangay Lagao General Santos Telephone No.: 552-3824; Telefax No.: 553-4960 Email Address: gscwdprocurement@yahoo.com

REQUEST FOR QUOTATION

DATE: 7/16/2024

RFQ #:3-0724-050

nortest time of delivery and submit you not later than 7/20/2024, Pls. furnish terms and conditions contained therein. sh this Request for Quotation duly, correct lter the contents of this form in any way. ical Specifications/ Terms of Reference is	this off	tion dulfice the complete, prospec	ly signed by your following articles ly.
DESCRIPTION	QTY.	UNIT	UNIT PRICE
AVR 220 VOLTS: 3KW, SERVO TYPE AVR, PLEASE SEE ATTACHED SPECIFICATIONS-ABC: PHP 32,000.00 AVR 220 VOLTS: 5KW, SERVO TYPE AVR, PLEASE SEE ATTACHED SPECIFICATIONS-ABC: PHP 45,000.00 ########### nothing follows ############	1	unit	P
GSCWD Bodega livery allowed**** NG TAX DEDUCTION	Price q		lier
	nortest time of delivery and submit you not later than 7/20/2024 , Pls. furnish terms and conditions contained therein. sh this Request for Quotation duly, correct lter the contents of this form in any way. ical Specifications/ Terms of Reference is service provider) must indicate and signifunct the specification. DESCRIPTION AVR 220 VOLTS: 3KW, SERVO TYPE AVR, PLEASE SEE ATTACHED SPECIFICATIONS-ABC: PHP 32,000.00 AVR 220 VOLTS: 5KW, SERVO TYPE AVR, PLEASE SEE ATTACHED SPECIFICATIONS-ABC: PHP 45,000.00 ########### nothing follows ####################################	nortest time of delivery and submit your quotanot later than 7/20/2024, Pls. furnish this offiterms and conditions contained therein. sh this Request for Quotation duly, correctly, and liter the contents of this form in any way. ical Specifications/ Terms of Reference is provided service provider) must indicate and signify complinate the specification. DESCRIPTION AVR 220 VOLTS: 3KW, SERVO TYPE AVR, PLEASE SEE ATTACHED SPECIFICATIONS-ABC: PHP 32,000.00 AVR 220 VOLTS: 5KW, SERVO TYPE AVR, PLEASE SEE ATTACHED SPECIFICATIONS-ABC: PHP 45,000.00 ########### nothing follows ####################################	sh this Request for Quotation duly, correctly, and complete lter the contents of this form in any way. ical Specifications/ Terms of Reference is provided, prosper service provider) must indicate and signify compliance to in the specification. DESCRIPTION



Republic of the Philippines GENERAL SANTOS CITY WATER DISTRICT

E. Fernandez St., Brgy. Lagao, General Santos City Telephone No. (083) 552-3824/ Telefax No. (083) 553-4960 E-mail Address: gscwaterdistrict@yahoo.com www.gensanwater.gov.ph

TECHNICAL SPECIFICATION

TITLE: PURCHASE OF 3kW Voltage Regulator Stabilizer Servo Motor Type

SCOPE OF CONTRACT

The scope shall be supply of One (1) unit brand new Voltage Regulator Stabilizer Servo Motor Type to General Santos City Water District (GSCWD).

Requirements	Statement of Compliance
3kW AVR Stabilizer Servo Motor Type	
Controlled by Servo Motor	
w/ Power ON Time Delay (3-5mins)	
High / Low Voltage Cut-off protection	
Input: AC190V - 260V	
Output outlet: AC110V x2, AC220V x2	
One year Warranty	

Prepared by:

EDMUND L. BADAL, REE

TWG - Member

MICHAEL & GABALES, REE

TWG-HEAD

SITY WATER BISTRIC

Republic of the Philippines GENERAL SANTOS CITY WATER DISTRICT

E. Fernandez St., Brgy. Lagao, General Santos City Telephone No. (083) 552-3824/ Telefax No. (083) 553-4960 E-mail Address: gscwaterdistrict@yahoo.com www.gensanwater.gov.ph

TECHNICAL SPECIFICATION

TITLE: PURCHASE OF 5kW Voltage Regulator Stabilizer Servo Motor Type

SCOPE OF CONTRACT

The scope shall be supply of One (1) unit brand new Voltage Regulator Stabilizer Servo Motor Type to General Santos City Water District (GSCWD).

Requirements	Statement of Compliance
5kW AVR Stabilizer Servo Motor Type	
Controlled by Servo Motor	
w/ Power ON Time Delay (3-5mins)	
High / Low Voltage Cut-off protection	
Input: AC190V – 260V	
Output outlet: AC110V x2, AC220V x2	
One year Warranty	

Prepared by:

EDMUND L. BADAL, REE

TWG - Member

MICHAELO GABALES, REE