



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez Street, Barangay Lagao General Santos
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwdprocurement@yahoo.com

GPM-014-4

REQUEST FOR QUOTATION

RFQ #: 3-0724-052 DATE: 7/16/2024

SUPPLIER: _____
ADDRESS: _____
TELEPHONE NO. : _____
TIN NO. : _____

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 7/20/2024, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

Instructions :

1. Accomplish this Request for Quotation duly, correctly, and completely.
2. Do not alter the contents of this form in any way.
3. If Technical Specifications/ Terms of Reference is provided, prospect bidder (supplier / service provider) must indicate and signify compliance to every parameter in the specification.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	LIGHTNING ARRESTER (104-018-T) : PLEASE SEE ATTACHED SPECIFICATIONS-ABC: PHP 700,000.00 ##### nothing follows #####	2	pc	P

Date of Delivery: _____
Price Validity : _____
Mode of Payment: _____

Place of Delivery: GSCWD Bodega.

****No partial delivery allowed****

Note: 6% WITHHOLDING TAX DEDUCTION

PR NO.: 0624-061

Requested by:

Price quoted by:


Material Procurement Officer A

Supplier

Date



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF LIGHTNING ARRESTER

1.0 SCOPE OF CONTRACT

The scope shall be supply, delivery, installation and commissioning of Two (2) sets brand new Lightning Arrester to General Santos City Water District (GSCWD).

Requirements	Statement of Compliance
Lightning Arrester:	
Protection Performance 60 micro second Triggering Advance Time	
Double Action Early Streamer Emission	
ESE Lightning Conductor Radius of Protection: 107 Meters	
Streamer Lightning Stroke Counter	
Starting Threshold from 1 to 100 kA in 8/20 wave	
3 Digits Analog Display	
Grounding System:	
Copper Clad Ground Rod 3/4" x 10' (3 pcs.) per system	
PERMAWELD Exothermic Welding Connection	
Down Conductor:	
60 mm. Square, bare copper wire (as required number of Meters in length)	
A 60 mm square bare copper wire must be enclosed within the required electrical conduit to ensure adequate insulation.	



Pole:	
6 – 8 Meters Pole Mast, 2" G. I. Pipe, Schedule 40	
Adapter, Clamp, Can Stand Up to 200 km/h Wind	
Welding Support, Paint Job	
Earth Resistance Test and Certification	

TERMS AND CONDITIONS

Item No.	Requirements	Statement of Compliance
1	The scope of work shall be supply, delivery, installation and commissioning of Two (2) sets brand new Lightning Arrester to General Santos City Water District (GSCWD).	
2	All bidder is required to submit and include documents but not limited to manuals, data sheets and name plate specifications , in there bidding documents.	
3	The installation of lightning arresters is required at two separate locations, and all installation expenses will be the sole responsibility of the successful bidder.	
4	That during the installation and commissioning of the units, the winning bidder shall be required to send a technician/s responsible of installation and commissioning of the two units. All relevant and incidental cost (transportation, accommodation, allowances and etc.) in the commissioning of the equipment shall be shouldered by the winning bidder.	
5	The lightning arresters and installation must comply with all relevant local, national, and Philippine Electrical Code. The supplier is responsible for obtaining any necessary permits or approvals for the installation.	



6	The winning bidder shall deliver the Two (2) sets brand new Lightning Arrester within Sixty (60) calendar days upon receipt of Purchase Order (PO).	
7	The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.	
8	Any deficiencies or issues identified during the inspection shall be rectified by the winning bidder at no additional cost to GSCWD.	
9	The winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the unit. That the bidder must have an available qualified and trained technicians 24/7 in case of equipment failure.	

Prepared by:


EDMUND L. BADAL, REE
TWG - Member


MICHAEL G. GABALES, REE
TWG - HEAD

Recommending Approval:


ROGELIO A. BESANA JR., CE, RMP
AGM- Operation and Technical Services

Approval:


FRANCISCO R. ALOLOD, JR., CPA, CESE
Acting General Manager