



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
 E. Fernandez Street, Barangay Lagao General Santos
 Telephone No.: 552-3824; Telefax No.: 553-4960
 Email Address: gscwdprocurement@yahoo.com

GPM-014-4

REQUEST FOR QUOTATION

RFQ #: 3-0824-010 DATE: 8/6/2024

SUPPLIER: _____
 ADDRESS: _____
 TELEPHONE NO. : _____
 TIN NO. : _____

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 8/10/2024, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

Instructions :

1. Accomplish this Request for Quotation duly, correctly, and completely.
2. Do not alter the contents of this form in any way.
3. If Technical Specifications/ Terms of Reference is provided, prospect bidder (supplier / service provider) must indicate and signify compliance to every parameter in the specification.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	CHLORINE BOOSTER PUMP : PLEASE SEE ATTACHED SPECIFICATIONS/ PICTURE-ABC: PHP 175,000.00	5	pc	P
2	CHLORINE GAS REGULATOR : PLEASE SEE ATTACHED SPECIFICATIONS/ PICTURE-ABC: PHP 200,000.00	5	sets	P
3	CHLORINE GAS EJECTOR : PLEASE SEE ATTACHED SPECIFICATIONS/ PICTURE-ABC: PHP 140,000.00 ##### nothing follows #####	5	<ignor	P

Date of Delivery: _____
 Price Validity : _____
 Mode of Payment: _____

Place of Delivery: GSCWD Bodega
 *****No partial delivery allowed*****
 Note: 6% WITHHOLDING TAX DEDUCTION
 PR NO.: 0424-007

Requested by:

Price quoted by:

Andrew M. Nolasco, Jr.
 Material Procurement Officer A

 Supplier

 Date



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF BRAND-NEW CHLORINE BOOSTER PUMP

1.0 SCOPE OF CONTRACT

The scope shall be supply and delivery of brand new Chlorine Booster Pump to General Santos City Water District (GSCWD).

2.0 OPERATING REQUIREMENTS


Particulars	Requirements	Statement of Compliance
Maximum Flow, Lps (gpm)	1 (16)	
Maximum head, m(ft)	35(115)	
Discharge / Suction Connection, (inch)	1	
Design Speed (RPM)	3400-3600	
Pump Casing	Cast Iron	
Impeller Material	Stainless Steel 304	
Max. Pressure at stated temperature	6 bar/ 90°C	
Motor Rated Power (Hp)	1	
Rated Voltage	115/230	
Motor Windings	Pure Copper	
Enclosure Class	IP55	
Phase	1	
Design point	3400-3600RPM	
Protection	Thermal Protection	




3.0 TERMS AND CONDITIONS

Item No.	Requirements	Statement of Compliance
1	The scope of work shall be supply and delivery of brand new Chlorine Booster Pump to General Santos City Water District (GSCWD).	
2	All bidder is required to submit and include documents but not limited to manuals, data sheets, and Manufacturers Certificate in there bidding documents.	
3	Field testing shall be made once the units are ready for operation and when both the GSCWD and winning bidder have finished their scopes of work on the installed units. GSCWD engineers shall conduct field testing with the presence of winning bidder's representative.	
4	The winning bidder shall deliver the units within Thirty (30) calendar days upon receipt of Purchase Order (PO).	
5	The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.	
6	That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the pumping equipment.	
7	That the winning bidder shall have an available qualified and trained technicians 24/7 with in Mindanao area in case of equipment failure.	

Prepared by:


EDMUND L. BADAL, REE
TWG - Member

Approval:


MICHAEL G. GABALES, REE
TWG - HEAD



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF BRAND-NEW CHLORINE GAS REGULATOR

1.0 SCOPE OF CONTRACT

The scope shall be supply and delivery of brand-new Chlorine Gas Regulator to General Santos City Water District (GSCWD).

2.0 OPERATING REQUIREMENTS


Particulars	Requirements	Statement of Compliance
Body Components:	Hastelloy-C Inlet Valves Solid Machined PVC Construction Non-Metallic Inlet Adapter Titanium Body Fasteners	
Feed rate	Up to 250 PPD	
Max Operating Pressure:	300 psi	
Tubing Connection:	3/8" vacuum and vent	
Vacuum Regulator Mounting	Direct cylinder or manifold mounted with remote mounted meter panel with rate valve	
Operating Temperature	35°F to 120°F	
Accuracy:	Within 4% of max rotometer capacity	
Operating Range:	20:1, manual, 10:1, automatic	
Back Pressure:	140 psig	

3.0 TERMS AND CONDITIONS

Item No.	Requirements	Statement of Compliance
1	The scope of work shall be supply and delivery of brand new Chlorine Gas Regulator to General Santos City Water District (GSCWD).	



2	All bidder is required to submit and include documents but not limited to manuals, data sheets, and Manufacturers Certificate in there bidding documents.	
3	The winning bidder shall deliver the units within Thirty (30) calendar days upon receipt of Purchase Order (PO).	
4	The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.	
5	That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the pumping equipment.	
6	That the winning bidder shall have an available qualified and trained technicians 24/7 with in Mindanao area in case of equipment failure.	

Prepared by:


EDMUND L. BADAL, REE
TWG - Member

Approval:


MICHAEL G. SABALES, REE
TWG - HEAD



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF BRAND-NEW CHLORINE GAS EJECTOR

1.0 SCOPE OF CONTRACT

The scope shall be supply and delivery of brand-new Chlorine Gas Ejector to General Santos City Water District (GSCWD).

2.0 OPERATING REQUIREMENTS


Particulars	Requirements	Statement of Compliance
Body Components:	CNC Machined PVC Type 1	
Yield Strength	12,800 psi	
Springs:	Hastelloy C-276 or Tantalum (Ta)	
Diaphragms:	Thermal Formed Viton® with no color additives	
O-Rings & Gaskets:	Viton® with no color additives	
Discharge Connection:	1" NPT	
Nozzle:	0.161"(4.1mm)	
Ejector Assembly Water Pressure capacity	300 PSIG	
Vacuum system	By Fixed-throat venturi system the ejector creates a vacuum connected directly to the chlorine solution diffuser.	
Prevents water from entering the gas system with an O-Ring seal.	Diaphragm check valve system	
To allow close-coupling of the ejector	With solution diffuser	



3.0 TERMS AND CONDITIONS

Item No.	Requirements	Statement of Compliance
1	The scope of work shall be supply and delivery of brand new Chlorine Gas Ejector to General Santos City Water District (GSCWD).	
2	All bidder is required to submit and include documents but not limited to manuals, data sheets, and Manufacturers Certificate in there bidding documents.	
3	The winning bidder shall deliver the units within Thirty (30) calendar days upon receipt of Purchase Order (PO).	
4	The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.	
5	That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the pumping equipment.	
6	That the winning bidder shall have an available qualified and trained technicians 24/7 with in Mindanao area in case of equipment failure.	

Prepared by:


EDMUND L. BADAL, REE
TWG - Member

Approval:


MICHAEL G. GABALES, REE
TWG - HEAD