



Republic of the Philippines  
GENERAL SANTOS CITY WATER DISTRICT  
E. Fernandez Street, Barangay Lagao General Santos  
Telephone No.: 552-3824; Telefax No.: 553-4960  
Email Address: gscwdprocurement@yahoo.com

GPM-014-4

### REQUEST FOR QUOTATION

RFQ #: 3-0824-046      DATE: 8/13/2024

SUPPLIER: \_\_\_\_\_  
ADDRESS: \_\_\_\_\_  
TELEPHONE NO. : \_\_\_\_\_  
TIN NO. : \_\_\_\_\_

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 8/17/2024, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

Instructions :

1. Accomplish this Request for Quotation duly, correctly, and completely.
2. Do not alter the contents of this form in any way.
3. If Technical Specifications/ Terms of Reference is provided, prospect bidder (supplier / service provider) must indicate and signify compliance to every parameter in the specification.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	32MM (1-1/4``) DIA MULTI-JET BRASS WATER METER : PLEASE SEE ATTACHED SPECIFICATIONS-ABC: PHP 405,000.00	45	pc	P
2	40MM (1-1/2``) DIA MULTI-JET BRASS WATER METER : PLEASE SEE ATTACHED SPECIFICATIONS-ABC: PHP 420,000.00	35	pc	P
3	WATER METER 2`` (BRASS) : TAILPIECE TYPE (PLEASE SEE ATTACHED SPECIFICATIONS)-ABC: PHP 170,000.00 ##### nothing follows #####	10	pcs	P

Date of Delivery: \_\_\_\_\_  
Price Validity : \_\_\_\_\_  
Mode of Payment: \_\_\_\_\_

Place of Delivery: GSCWD Bodega

\*\*\*\*No partial delivery allowed\*\*\*\*

Note: 6% WITHHOLDING TAX DEDUCTION

PR NO.: 0824-028

Requested by:

Price quoted by:

**ANDREW H. NADAL, JR.**  
Material Procurement Officer A

\_\_\_\_\_  
Supplier

\_\_\_\_\_  
Date



**PURCHASE OF FORTY-FIVE (45) PIECES 32 MM Ø, THIRTY-FIVE (35) PIECES 40MM Ø AND TEN (10) PIECES 50MM Ø MULTI-JET BRASS WATER METER**


Project Title : Purchase of forty-five (45) pieces 32 mm Ø, thirty-five (35) pieces 40mm Ø and ten (10) pieces 50mm Ø multi-jet brass water meter  
 ABC : Php995, 000.00 (45 pcs 32mm P405,000.00; 35 pcs 40mm P420,000.00 & 10 pcs 50mm P170,000.00)  
 Owner : General Santos City Water District  
 Scope of Work : The scope of work shall be the supply, testing and delivery of water meters to General Santos City Water District.


I. GENERAL REQUIREMENTS						STATEMENT OF COMPLIANCE
A. NOMINAL DIAMETER	32 MM, 40 MM and 50MM					
B. METER TYPE	Multi-jet					
C. METROLOGICAL CLASS	ISO 4064 Class B or equivalent to its latest edition					
D. METER DESIGN	Flow is bi-directional ( <i>no non-returned valve at outlet portion</i> )					
	Meter registry is irreversible					
	Hermetically or vacuum sealed register					
	Solid and Robust design, high impact glass lens & pressure resistance.					
	Anti-magnetic type					
	Water meter body and register box ring shall be made of brass.					
	Meter register in cubic meters (m <sup>3</sup> )					
E. DIMENSION		DN 32	DN 40	DN 50	Tolerance	
	Length w/o tailpieces; mm	250-280	290-320	280-310		
	Width; mm	103	130	130	±5mm	
	Height; mm	125	158	158	±5mm	
	Weight; kg	2.5-3.0	5.0-5.5	6.5-7.5		
	Connectors; inch Ø	1-1/2	2.0	2-1/2		
F. METROLOGICAL CHARACTERISTICS (MINIMUM PERFORMANCE)	Flowrate	DN 32	DN 40	DN 50	% Error	
	Qmin; m <sup>3</sup> /h	0.12	0.20	0.45	±5 %	
	Qt; m <sup>3</sup> /h	0.48	0.80	3.0	±2 %	
	Qmax; m <sup>3</sup> /h	12.0	20.0	30.0	±2%	
	Qn; m <sup>3</sup> /h	6.0	10.0	15.0	±2 %	
<b>Note: Application of flowrates for each size during testing will be based on its Metrological Class</b>						
G. WORKING CONDITION	Working Pressure: 10-17 Bars					
	Water Temperature: The meter can work without deterioration on temperature at local climate					
H. STRAINER SCREEN	Meter fitted with strainer on inlet to protect against dirt					

II. ADDITIONAL REQUIREMENTS:		STATEMENT OF COMPLIANCE
A. TECHNICAL BROCHURE	Bidders are required to submit technical brochure/ specifications for further evaluation of the offered product.	
	In lieu of submitting water meter sample for weight verification purposes, bidders shall submit photo of the offered water meter been weigh by a measuring instrument for 32mm, 40mm and 50mm respectively.	
B. EFFICIENCY TEST	One percent (1%) of the total quantity of each size shall undergo random water meter test in Meter Testing Laboratory. The winning bidder shall pay the corresponding cost of testing.	
	If twenty percent (20%) of the total number of water meters tested Failed the efficiency test, the procuring Entity (GSCWD) shall have the option to rescind or cancel the contract.	
	Random water meter testing shall be witnessed by three (3) GSCWD representatives. All costs such as transportation, hotel accommodation, meals, allowances and other related expenses shall be borne by the winning supplier. Testing shall be completed in one (1) day excluding travel period.	
	There shall be a representative from the winning bidder during random testing.	
	The water meters shall be randomly tested for accuracy in a Water Meter Laboratory for Transitional and Minimum flow rates. These flow rates shall be the basis for the meter to PASS or FAIL in the Accuracy Test.	
C. TERMS OF DELIVERY	45 pcs 32mm, 35 pcs 40mm and 10 pcs 50mm Multi-jet Brass Water Meter Complete Sets – 60 Calendar Days upon receipt of Purchase Order. (One-time delivery)	
D. OTHER PACKAGE	With plastic end cap installed to both meter body thread ends.	
	Each meter individually packed in a small box containing 2 threaded tailpieces/connectors and 2 rubber gasket that fitted to its outlet design of the manufacturer.	
	The winning bidder shall provide additional 18 pcs for 32mm, 14 pcs for 32mm and 4 pcs 50mm rubber gaskets and an additional 18 pcs for 32mm, 14 pcs for 32mm and 4 pcs 50mm connectors/tailpieces.	
	It shall be packed by 10's per batch with the meter serial numbers indicated in the external portion of carton/box.	
E. BIDDERS QUALIFICATION	Bidder shall be an authorized dealer / reseller of the offered product for after sales and support.	


Prepared by:

**TECHNICAL WORKING GROUP FOR WATER METER**

  
**MARY ANN SANDY D. PINOS, ME**  
 TWG - Member

  
**MICHAEL G. GABALES, REE**  
 TWG - Head

Recommending Approval:  
  
**FERDINAND S. FERRER, MPA**  
 AGM - Administration

Approved by:  
  
**FRANCISCO R. ALOLOD JR., CPA, CESE**  
 Acting General Manager