



Republic of the Philippines  
GENERAL SANTOS CITY WATER DISTRICT  
E. Fernandez Street, Barangay Lagao General Santos  
Telephone No.: 552-3824; Telefax No.: 553-4960  
Email Address: gscwdprocurement@yahoo.com

GPM-014-2

### REQUEST FOR QUOTATION

RFQ #: 3-1022-019      DATE: 10/06/2022

SUPPLIER: \_\_\_\_\_  
ADDRESS: \_\_\_\_\_  
TELEPHONE NO. : \_\_\_\_\_  
TIN NO. : \_\_\_\_\_

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 10/12/2022, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	SUBMERSIBLE CABLE ROUND : 60MM <sup>2</sup> , SEE ATTACHED SPECIFICATIONS-ABC: PHP 375,000.00	75	mtrs	P
2	SUBMERSIBLE CABLE ROUND : 80MM <sup>2</sup> , SEE ATTACHED SPECIFICATIONS-ABC: PHP 435,000.00 ##### nothing follows #####	75	mtrs	P

Date of Delivery: \_\_\_\_\_  
Price Validity : \_\_\_\_\_  
Terms of Payment: \_\_\_\_\_

Place of Delivery: GSCWD Bodega

\*\*\*\*No partial delivery allowed\*\*\*\*

Note: 6% WITHHOLDING TAX DEDUCTION

PR NO.: 0922-073

Requested by:

**OFFICER A**  
MATERIAL PROCUREMENT  
OFFICER A

Price quoted by:

\_\_\_\_\_  
Supplier

\_\_\_\_\_  
Date



## **TECHNICAL SPECIFICATION**

### **TITLE: PURCHASE OF BRAND NEW SUBMERSIBLE CABLE**

#### **1.0 SCOPE OF CONTRACT**

The scope shall be supply of two (2) brand Submersible Cable to General Santos City Water District (GSCWD).

#### **2.0 Submersible cable requirements**

<b>Particulars</b>	<b>Requirement</b>		<b>Statement of Compliance</b>
<b>Type</b>	<b>Round</b>	<b>Round</b>	
<b>Size (mm<sup>2</sup>)</b>	<b>60</b>	<b>80</b>	
<b>Length (meters)</b>	<b>75</b>	<b>75</b>	
<b>No. of Leads</b>	<b>3</b>	<b>3</b>	
<b>Maximum Operating Temperature (°C)</b>	<b>75</b>	<b>75</b>	
<b>All Submersible Cables shall be PVC- insulated with PVC &amp; PE jacket</b>			





### 3.0 TERMS AND CONDITIONS

Item No.	Requirements	Statement of Compliance
1	The scope of work shall be supply Submersible Cable to General Santos City Water District (GSCWD).	
2	All bidder is required to submit and include documents but not limited to manuals, data sheets, and <b>Manufacturers Certificate</b> .	
3	The winning bidder shall deliver the units within <b>Ninety (90)</b> calendar days upon receipt of Purchase Order (PO). Laboratory testing is included in the 90-calendar day's delivery period.	
4	The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.	
5	The submersible motor and cable must comply with PEC standard as to their current rating.	
6	That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning the submersible cable.	

Prepared by:

  
**EDMUNDO L. BADAL, REE**  
TWG - Member

  
**MICHAEL G. GABALES, REE**  
TWG - HEAD