



Republic of the Philippines  
GENERAL SANTOS CITY WATER DISTRICT  
E. Fernandez Street, Barangay Lagao General Santos  
Telephone No.: 552-3824; Telefax No.: 553-4960  
Email Address: gscwdprocurement@yahoo.com

GPM-014-4

### REQUEST FOR QUOTATION

RFQ #: 3-1024-079 DATE: 10/24/2024

SUPPLIER: \_\_\_\_\_  
ADDRESS: \_\_\_\_\_  
TELEPHONE NO. : \_\_\_\_\_  
TIN NO. : \_\_\_\_\_

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 10/28/2024, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

Instructions :


1. Accomplish this Request for Quotation duly, correctly, and completely.
2. Do not alter the contents of this form in any way.
3. If Technical Specifications/ Terms of Reference is provided, prospect bidder (supplier / service provider) must indicate and signify compliance to every perimeter in the specification.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	TRANSFORMER DISTRIBUTION 50KVA : 50kVA, Industrial type, Primary: 7620V/13.2kV, Secondary: 480V-ABC: PHP 480,000.00 ##### nothing follows #####	3	unit	P

Delivery Term: \_\_\_\_\_  
Price Validity : \_\_\_\_\_  
Mode of Payment: \_\_\_\_\_

Place of Delivery: GSCWD Bodega  
\*\*\*\*\*No partial delivery allowed\*\*\*\*  
Note: 6% WITHHOLDING TAX DEDUCTION  
PR NO.: 1024-033

Requested by:

  
ARNOLD S. NINALADA  
Clerk/Processor C

Price quoted by:

\_\_\_\_\_  
Supplier

\_\_\_\_\_  
Date



## TECHNICAL SPECIFICATION

### TITLE: PURCHASE OF 50KVA POLE MOUNTED TRANSFORMER

#### 1.0 General Scope

The scope of work shall be supply and delivery of Pole mounted transformer to General Santos City Water District.

#### 2.0 General Specification

Item	Technical Specification	Statement of Compliance
1	Mineral oil emmersed (Silicon / Amorphous)	
2	Three (3) units x 50kVA	
3	Industrial type	
4	60Hz	
5	Single phase	
6	Cu-Cu windings	
7	Capacity: 50kVA	
8	Primary: 7620V/13.2kV	
9	Secondary: 480V	

#### 3.0 TERMS AND CONDITIONS

1. The successful bidder is required to submit the following but not limited to data sheets and operating manual.
2. The successful bidder shall deliver the of Pole mounted transformer within **Sixty (60)** calendar days upon receipt of Purchase Order (PO).
3. Insulation test shall be conducted by Socoteco II before installation of Pole mounted transformer. Testing shall be witnessed by two (2) GSCWD



Republic of the Philippines  
GENERAL SANTOS CITY WATER DISTRICT (GSCWD)

GSCWD Bldg., E. Fernandez Street (Emergency Road), Lagao, General Santos City  
Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960  
E-mail Address: gscwaterdistrict@yahoo.com

---

- representatives together with the winning bidder's representatives for half (1/2) day. All relevant and incidental cost (Testing fee and Transportation) in the testing of the equipment shall be shouldered by the winning bidder.
4. The successful bidder must ensure the presence of skilled and trained technicians around the clock (24/7) in the event of equipment malfunction.
  5. Moreover, the successful bidder must possess a boom truck that is readily accessible within six (6) hours from call to facilitate the essential repairs or replacement within its warranty period without cost to GSCWD.
  6. The successful bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.
  7. That the successful bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the unit.

Prepared by:

  
**EDMUND L. BADAL, REE**  
TWG - Member

  
**MICHAEL G. GABALES, REE**  
TWG - HEAD