



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez Street, Barangay Lagao General Santos
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwdprocurement@yahoo.com

GPM-014-4

REQUEST FOR QUOTATION

RFQ #: 3-1024-081 DATE: 10/24/2024

SUPPLIER: _____
ADDRESS: _____
TELEPHONE NO. : _____
TIN NO. : _____

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 10/28/2024, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

Instructions :


1. Accomplish this Request for Quotation duly, correctly, and completely.
2. Do not alter the contents of this form in any way.
3. If Technical Specifications/ Terms of Reference is provided, prospect bidder (supplier / service provider) must indicate and signify compliance to every perimeter in the specification.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	TRANSFORMER DRY TYPE STEP DOWN 10 KVA : PLEASE SEE ATTACHED SPECIFICATION-ABC: PHP 220,000.00 ##### nothing follows #####	2	unit	P

Delivery Term: _____
Price Validity : _____
Mode of Payment: _____

Place of Delivery: GSCWD Bodega
****No partial delivery allowed****
Note: 6% WITHHOLDING TAX DEDUCTION
PR NO.: 1024-032

Requested by:


ARNOLD S. NINALADA
Clerk Processor C

Price quoted by:

Supplier

Date



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF DRY TYPE STEP DOWN TRANSFORMER

1.0 General Scope

The scope of work shall be supply and delivery of Dry type step down transformer to General Santos City Water District.

2.0 General Specification

Item	Technical Specification	Statement of Compliance
1	Dry Type Transformer, 60Hz, Single phase, copper windings with powder coated enclosure	
2	Capacity: 10kVA	
3	Primary: 460V	
4	Secondary: 230V	
5	Voltage drop: 3.3%	
6	Primary and secondary connections on copper plates	
7	With enclosure (IP21 degree of protection)	
8	220°C insulation materials	

3.0 TERMS AND CONDITIONS

1. The scope of work shall be supply and delivery of Dry type step down transformer to General Santos City Water District (GSCWD).
2. The winning bidder is required to submit the following but not limited to data sheets and operating manual.





Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT (GSCWD)

GSCWD Bldg., E. Fernandez Street (Emergency Road), Lagao, General Santos City
Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960
E-mail Address: gscwaterdistrict@yahoo.com

3. The winning bidder shall deliver the Dry type step down transformer within **Sixty (60)** calendar days upon receipt of Purchase Order (PO).
4. That the winning bidder shall have an available qualified and trained technicians 24/7 in case of equipment failure.
5. The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.
6. That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the unit.

Prepared by:


EDMUND L. BADAL, REE
TWG - Member


MICHAEL G. GABALES, REE
TWG - HEAD