



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez Street, Barangay Lagao General Santos
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwdprocurement@yahoo.com

GPM-014-2

REQUEST FOR QUOTATION

RFQ #: 3-1221-007 DATE: 01/13/2022

SUPPLIER: _____
ADDRESS: _____
TELEPHONE NO. : _____
TIN NO. : _____


Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 01/19/2022, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	AUTOMATIC TRANSFER SWITCH : 300 AMPS, 35KAIC, 460V-ABC: PHP 450,000.00	1	unit	P
2	TRANSFORMER DRY TYPE STEP DOWN 10 KVA : SINGLE PHASE, 460V/230V-ABC: PHP 150,000.00 ##### nothing follows #####	1	unit	P

Date of Delivery: _____
Price Validity : _____
Terms of Payment: _____

Place of Delivery: GSCWD Bodega
*****No partial delivery allowed****
Note: 6% WITHHOLDING TAX DEDUCTION
PR NO.: 0421-081

Requested by:

GESEM R. CABAÑERO
MATERIAL PROCUREMENT
OFFICER A

Price quoted by:

Supplier

Date



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF AUTOMATIC TRANSFER SWITCH

1.0 General Scope

The scope of work shall be supply, delivery and commissioning of Automatic Transfer Switch to General Santos City Water District.

2.0 General Specification

Item	Technical Specification	Statement of Compliance
1	Pre-wired Automatic Transfer Switch Panel complete with powder coated wall mounted enclosure, dead-front breaker compartment and swing type front door, door mounted accessories and with following major components below.	
2	Electrically operated Molded Case Circuit breaker rated 2x300A, 3P, 60Hz, 35kAIC.	
3	ATS Digital Controller, door mounted, LED display with manual and remote functions.	
4	Digital multi-function power meter with dual source for utility & generator.	
5	Ring type current transformers.	



6	Copper busbar @100% rated capacity including ground bus	
7	Complete controller accessories with interlink to generator controller for remote start.	

3.0 TERMS AND CONDITIONS

1. The scope of work shall be supply, delivery and commissioning of Automatic Transfer Switch with complete accessories to General Santos City Water District (GSCWD).
2. The winning bidder is required to submit the following but not limited to data sheets, operating manual, troubleshooting manual, programming manual, software for programming the unit and single line diagram.
3. The winning bidder shall deliver the Automatic Transfer Switch within **Thirty (30)** calendar days upon receipt of Purchase Order (PO).
4. The winning bidder shall conduct Onsite personnel training and orientation for Parameter and protection settings.
5. **Certificate of completion shall be release only if** the Generator will remotely start and properly interlock with the Automatic Transfer Switch supplied.
6. That the winning bidder shall have an available qualified and trained technicians 24/7 in case of equipment failure.
7. The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT (GSCWD)
GSCWD Bldg., E. Fernandez Street (Emergency Road), Lagao, General Santos City
Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960
E-mail Address: gscwaterdistrict@yahoo.com


8. That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the unit.

Prepared by:


EDMUND L. BADAL, REE
TWG - Member


MICHAEL G. GABALES, REE
TWG - HEAD

Recommending Approval:


ROGELIO A. BESANA JR. C.E./RMP
Assistant General Manager

Approval:


ARN B. GELLANGARIN, PME
General Manager A



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF DRY TYPE STEP DOWN TRANSFORMER

1.0 General Scope

The scope of work shall be supply and delivery of Dry type step down transformer to General Santos City Water District.

2.0 General Specification

Item	Technical Specification	Statement of Compliance
1	Dry Type Transformer, 60Hz, 1P, copper windings with powder coated enclosure	
2	Capacity: 10kVA	
3	Primary: 460V	
4	Secondary: 230V	
5	Voltage drop: 3.3%	
6	Primary and secondary connections on copper plates	
7	IP21 degree of protection	
8	220°C insulation materials	

3.0 TERMS AND CONDITIONS

1. The scope of work shall be supply and delivery of Dry type step down transformer to General Santos City Water District (GSCWD).
2. The winning bidder is required to submit the following but not limited to data sheets and operating manual.



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT (GSCWD)
GSCWD Bldg., E. Fernandez Street (Emergency Road), Lagao, General Santos City
Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960
E-mail Address: gscwaterdistrict@yahoo.com


3. The winning bidder shall deliver the Dry type step down transformer within **Thirty (30)** calendar days upon receipt of Purchase Order (PO).
4. That the winning bidder shall have an available qualified and trained technicians 24/7 in case of equipment failure.
5. The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.
6. That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the unit.

Prepared by:


EDMUND L. BADAL, REE
TWG - Member


MICHAEL G. GABALES, REE
TWG - HEAD

Recommending Approval:


ROGELIO A. BESANA JR. C.E./RMP
Assistant General Manager

Approval:


ARN B. GELLANGARIN, PME
General Manager A